

COMMONWEALTH OF KENTUCKY  
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF JUDY WATER	)	
ASSOCIATION FOR A DEVIATION FROM THE	)	
REQUIREMENTS OF 807 KAR 5:066, SECTION	)	CASE NO.
10(2)(A) REGARDING DISTRIBUTION SYSTEM	)	2000-488
CONSTRUCTION REQUIREMENTS	)	

O R D E R

On November 1, 2000, Judy Water Association (“Judy Water”) applied for authority to deviate from Administrative Regulation 807 KAR 5:066, Section 10(2)(a), which prohibits a non-circulating 2-inch diameter water line from exceeding 250 feet in length. Judy Water requests this deviation for two 2-inch water line extensions in the Plantations Subdivision of Bath County, Kentucky. The first water line is approximately 450 feet in length, runs along Appaloosa Lane, and serves 2 customers. The other water line at issue is approximately 850 feet in length, runs along Trotter’s Trail, and serves 2 customers.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. Neither water line in question is within the maximum limits set forth in Administrative Regulation 807 KAR 5:066, Section 10(2)(a).
2. The hydraulic studies submitted for these water lines indicate that the flows of water can be provided to serve the customers at the standard pressure and their peak requirements.

IT IS THEREFORE ORDERED that:


1. Judy Water is granted a deviation from the maximum length requirements set forth in Administrative Regulation 807 KAR 5:066, Section 10(2)(a), for the two water line extensions identified in its application.

2. Judy Water shall not make additional connections to the water lines identified in its application without prior Commission approval.

Done at Frankfort, Kentucky, this 1<sup>st</sup> day of December, 2000.

By the Commission

ATTEST:

  
Executive Director